

FIRE RISK ASSESSMENT - Specialised Housing (Independent Living) (v4. August 2017)

Regulatory Reform (Fire Safety) Order 2005: Sleeping Accommodation

The purpose of the fire risk assessment is to evaluate the risk to people from fire, particularly vulnerable residents, taking into account existing fire safety measures, and to determine whether additional measures are necessary. The report does not address the risk to property or business continuity from fire.

The Regulatory Reform (Fire Safety) Order applies to the common areas of the building and the fire safety facilities provided in support of the building.

This fire risk assessment has not involved destructive inspection of the building, such as opening up of construction. However, where practicable, assessors should lift a sample of accessible false ceiling tiles, open a sample of service risers and inspect reasonably accessible roof voids (if present).

It will normally be necessary to gain limited entry to at least a sample of flats to examine the necessary measures (fire-resisting, self-closing entrance door; fire detection; monitoring of fire detection) to ensure that, when a fire occurs in a resident's accommodation, there is no undue risk to other residents.

This fire risk assessment considers the 'general fire precautions' defined in the FSO, the principal precautions for specialized housing are:

- A. Measures to reduce the risk of fire and the risk of the spread of fire
- B. Means of escape from fire and to ensure that escape routes can be safely and effectively used
- C. Measures to ensure automatic detection and early warning of fire
- D. Measures to mitigate the effects of fire (FFE)
- E. An emergency plan, including procedures for residents in the event of fire
- F. Fire Risk Management (inc. training of staff)

| RISK ASSESSMENT RATINGS | | |
|--|--------|---|
| Definition of priorities (where applicable): | | |
| Urgent | HIGH | Immediate action required or, if it is not feasibly practical to immediately resolve the issue, it is strongly recommended that a written programme be put in place for resolving and remedial measures put in place to control the risk in the interim period. Considerable resources should be provided to resolve. |
| Strongly recommended | MEDIUM | It is essential that efforts are made to reduce the risk in the short/medium term. Risk reduction measures, which should take cost into account, should be implemented within a defined time period. |
| Recommended | LOW | Action required in the longer term, some resources allocated and a programme put in place. |

The above table relates to the risk to determine which risks should be addressed first and the best allocation of resources.

Regardless of the severity of the rating, easy actions to resolve, (i.e. closing propped open fire doors), should be done as soon as practically possible. More difficult actions to resolve that may result in alteration to building fabric etc. should be programmed in depending on their severity and difficulty to resolve. The amount of resources allocated to an action is dependent on risk.

INITIAL INFORMATION

Scheme Name **Thomas Place**

Form ID **FRA-2422**

Does the scheme require a full onsite Fire Risk Assessment: **Yes**

FIRE RISK ASSESSMENT

Specialised Housing - Independent Living
(v2. April 2016)

Regulatory Reform (Fire Safety) Order 2005

Category of Premises against the FSO 2005: Sleeping Accommodation

The purpose of this report is to provide an assessment of the risk to life from fire in the building, and, where appropriate, to make recommendations to ensure compliance with fire safety legislation. The report does not address the risk to property or business continuity from fire.

The Regulatory Reform (Fire Safety) Order applies to the common areas of the building and the fire safety facilities provided in support of the building.

Fire Risk Assessment Type **Type 1 – Common parts only (non-destructive)**

Responsible Person **Housing 21**

Court Address **James Whatman Way, MAIDSTONE**

Court Manager **Lisa Tyler**
(Fire Safety Manager)

Do you wish to change Court Manager? **No**
New Court Manager

Property Service Manager **Pete Phillips**

Do you wish to change the Property Service Manager? **No**
New Property Service Manager

Fire Risk Assessor **Frank Ling**

Date of Fire Risk Assessment **10/09/2024**

Date of Previous Fire Risk Assessment **25/09/2023**

Suggested date for review
12 months or sooner if:

- Any structural or material change to the premises;
- A change of work practice;
- A near miss or fire incident;
- A significant change in staff levels.

The Building

Is the building purpose built for its intended use? **Yes**

It is assumed that compartmentation was at an adequate standard at the time of construction.

Is it a conversion that is believed to have been converted in accordance with Building Regulations?

| | |
|------------------|-------------------|
| Number of floors | 8 |
| Number of flats | 57 |
| Date Built | 13/02/2012 |
| Age of building | 12 |
| Scheme type | Extra Care |

Scheme type Other

Brief details of construction **Modern medium rise housing scheme comprising of flats and communal facilities for the use of residents, appointed to the scheme is a local housing manager who's role it is to manage the daily running of the scheme including tasks connected to fire safety, such as weekly/monthly compliance tests, PCFRA's and placing orders with service contractors. The role does not include any care of the occupants. The scheme is has been constructed utilising a concrete load bearing frame and floors with an insulated rendered panel system to the external walls. Following investigations the external wall system has been removed completely to all elevations and replaced to the requirement of Approved Document B4 (2022), all materials performing to Euro class A1 designation, non flammable, as incorporated into the StoTherm mineral render system. This comprises of a cement partical board fixed to metal stud work, mineral fibre insulation batts mechanically fixed to a carrier board and then rendered with a multi layer cementitious render. Horizontal and vertical fire barriers have been installed at all vertical and horizontal party wall/flat junctions, floor junctions and window reveals within the system. Kent FRS and Local BCO have undertaken comprehensive design reviews of the supplied design and undertaken site inspections to ensure the system and its application are inline with required BS and Building regulations. Vertical circulation via single escape stair and single fire person lift, the stairwell has been designated as a protected refuge area. Horizontal circulation via corridors subdivided by cross corridor fire compartment doors (FD60s). The roof is a flat roof design with no roof void or access by the residents. Within the building there are facilities managed and supplied by outside agencies, Hair Salon and commercial kitchen these are provided on a tenancy basis with H21 responsible for all fire safety compliance testing and maintenance.**

Do the elements of construction between flats and the common areas i.e. walls, floors, landings, stairwells and ceilings appear from a visual inspection to be in good condition? **Yes**

Please Specify

From a head and shoulders inspection of an accessible roof void does the roof void compartmentation appear to be adequate and in good condition? **N/A**

Location of loft latches **N/A**

Are the loft latches lockable? **N/A**

Approximate quantity of loft latches **0**

Are there any additional compartmentation requirements? **N/A**

Please specify

Are the walls or ceiling linings within the premises considered combustible? **No**

Please specify

Is an external wall cladding system present (inclusive of window and infill panels)? **Yes**

Cladding

| Cladding Type | If Other Please Specify | Percentage of Cladding Present | Comments |
|----------------------|-------------------------|--------------------------------|--|
| Render system | | 100 | Cement based gypsum render system as described elsewhere. |

Insulation

| Insulation type | If Other Please Specify | Comments |
|---------------------|-------------------------|--|
| Mineral Wool | | Rockwool RWA45 Euroclass A1 fire rated rigid mineral slab |

Are balconies present? **No**

Construction Materials

Is there any evidence of unsafe disposal of smoking materials and the misuse of barbeques?

Taking into account construction materials and geometry, does the balcony adequately resist the spread of fire over the walls and from one building to another?

Timber Framed **No**

Please provide further details

Section 1 Summary / Observations

Imagery

Means of Giving Warning in Case of Fire

Is there a manually operated fire alarm system provided? **Yes**

Is there automatic fire detection provided? **Yes**

Provide a description of the fire alarm system in place. i.e., An addressable Part 1 system in the communal areas extending a heat detector into the hallway of each flat and a Part 6 system in flats all linked to the Alarm Receiving Centre. L2 & LD1

Gent zoned addressed fire panel designd to meet the requirements of an L2 - BS:5839Coverage extends to flats, (hallways, living rooms, kitchens) escape routes, and all rooms off escape routes including the commercial kitchen, dining areas, lounges, offices, buggy room, hair salon, laundry room. Activation of the alarm also operates the AOV system and activates freeswing door closers fitted to all cross corridor fire doors and flat entrance doors.

Is there automatic and remote fire alarm signal transmission?

Yes

In the event of a communal fire alarm activation does the lift automatically ground to the nearest exit level?

Yes

Does the Court Manager fully understand the fire evacuation strategy for the building?

Yes

Is a zone plan in place?

Yes

Section 2 Summary / Observations

Imagery

Details of Fire Loss

Has there been any impact to the building as a result of fire? **No**

Details of Fire Loss

Summary / Observations

Imagery

The Occupant – Information Provided by the Court Manager

Maximum number sleeping within individual flats (approximate) **55**

Maximum number of employees at any one time (approximate) **1**

Maximum number of visitors/others at any one time (assumed) **65**

Are arrangements in place to ensure that where necessary, person-centred fire risk assessments have been carried out for high risk residents? **Yes**

Quantify high-risk residents and detail whether support would be required from the attending fire and rescue service to assist them to a relative place of safety. Ensure details of the specific residents and their requirements can be found in the folder located in the red fire box.

Following the PCFRA reviews undertaken it has been identified a number of occupants would require assistance to evacuate or respond to the alarms in the event of a fire, this is due to varying degrees of mobility issues and mental incapacity. Where occupants have been identified as high risk measures are in place to reduce and manage the risks, where appropriate KFRS have been made aware and engage with the occupants.

Has a Fire Emergency Evacuation Plan been carried out on all residents where required (high risks)? **Yes**

Are there communal rooms present that require an occupancy limit e.g., communal lounges and dining rooms?

Yes

Communal Lounge and Dining Occupancy

If more than 60 people are present, then a minimum of two separate exits are required. For two exits from a room to be considered alternative they should be located at least 45° apart. This prevents having to walk directly towards a fire when there are large numbers of people present or long escape routes.

The calculated occupant capacity should be determined by using 1 M2 per person for areas such as dining, lounge/common rooms.

In the event of a fire then it is always assumed that one exit is unavailable, and this is always the largest exit

Occupancy Figures with 1 Available Exit

| Max No. of Persons | Minimum Clear Opening |
|--------------------|-----------------------|
| 60 | 750mm |
| 110 | 850mm |
| 220 | 1050mm |

| | |
|---------------|-----------------|
| More than 220 | +5mm per person |
|---------------|-----------------|

| Room Type | Room | Occupancy Limit |
|--------------------|---|-----------------|
| Lounge | Communal lounge only accessible to the occupants of the scheme | 60 |
| Dining Room | Ground floor dininig room this is open to the public and forms part of the catering kitchen locality | 60 |

Summary / Observations

Imagery

Evacuation Strategy and Training

What is the current Fire Evacuation Strategy? **Stay Put / Delayed**

Please Specify

Delayed / Stay Put Evacuation

A delayed or stay put evacuation strategy requires the residents to remain in their individual flats until such time as a decision is made (usually by the fire service) to partly or fully evacuate the building, moving the residents to a place of safety. Evacuation strategies are detailed in the Fire Risk Management document.

Has the Court Manager/Housing Manager, or designated member of staff, successfully completed the Fire Safety Manager course? **Yes**

Have the nominated fire wardens attended relevant training and are competent to respond to the fire alarm? **Yes**

On Extra Care court only, have all HC21 care staff completed Fire Warden eLearning **N/A**

Are all staff familiar with the Fire Evacuation Strategy? **Yes**

Please specify

Does the resident fire box information document reflect customers individual needs, risks and evacuation arrangement? **Yes**

Please specify

Summary / Observations

Care staff supplied by an outside agency, LHM has inducted them into the fire procedures and evac strategy. Duty holders within catering and hair salon required to update and review FRA periodically to identify the need to activate suppression system and gas shut off.

Imagery

Fire Hazards - Elimination & Control

Are electrical intakes/meter units within the common areas enclosed in construction likely to afford a nominal period of fire resistance? **Yes**

Please provide further details

Are reasonable measures taken to prevent fires of an electrical origin? **Yes**

Please specify

Fixed & Portable installations periodically inspected and tested? (last inspection date) **15/03/2024**

Communal hardwire testing carried out in the last 5 years? (last inspection date) **04/05/2021**

Evidence of PAT testing for mobility scooter charged in designated communal areas **No**

Suitable limitation in the use of trailing leads and adapters? **Yes**

A 'No Smoking' policy is adopted in internal communal areas. Smoking is permitted in individual private flats.

Is there a suitable designated external smoking location? **Yes**

Is there any evidence of breaches to the smoking policy? **No**

Does the basic security against arson appear reasonable? **Yes**

Are refuse storage arrangements suitable **Yes**

Are there any combustibles near the building that has potential for ignition? **No**

Is the use of portable heaters restricted as far as possible? **Yes**

Is the use of the more hazardous type (e.g. radiant bar fires or LPG appliances) avoided? **Yes**

Are fixed heating installations subjected to regular maintenance? **Yes**

Are reasonable measures taken to prevent fires as a result of cooking within the communal or commercial kitchen? **Yes**

Filters changed and ductwork cleaned regularly? **Yes**

Suitable fire-fighting equipment available? **Yes**

Does the building have a lightning protection system? **Yes**

Are there any other significant ignition sources that require consideration e.g. oxygen/mobility scooters? **No**

Please Provide Further Details:

Is the standard of housekeeping adequate? **Yes**

Are combustible materials separated from ignition sources? **Yes**

Avoidance of unnecessary accumulation/in appropriate storage of combustible materials or waste?
Yes

Appropriate storage of hazardous materials? **Yes**

Are routine in-house inspections of fire safety precautions undertaken? **Yes**

Is there satisfactory control over works carried out in the building by outside contractors (including 'hot work' permits? **Yes**

Are fire safety conditions imposed on outside contractors? **Yes**

Is there a sufficient management procedure in place for cleaning the filters in the communal tumble driers? **Yes**

Summary / Observations

Onsite care team isolate charging points within the buggy room nightly at 10pm, this is to be recorded.

Imagery

Fire Protection Measures

Is it considered that the building is provided with reasonable means of escape / fire exists in case of fire? **Yes**

Number of fire exits **3**

Number of staircases **1**

Are the means of escape suitable and compliant with regulations? **Yes**

Exits easily and immediately openable where necessary? **Yes**

Are escape routes unobstructed and free from: storage of combustible items or obstructions, flammable liquids or gases and free from tripping or slipping hazards? **Yes**

Reasonable distance of travel where there is a single direction of travel? **Yes**

Reasonable distance of travel where there are alternative means of escape? **Yes**

Fire exits open in the direction of escape where necessary? **Yes**

Avoidance of sliding or revolving doors as fire exits where necessary? **Yes**

Suitable protection to escape routes? **Yes**

Suitable fire protection for all inner rooms? **N/A**

Are mobility scooter being charged or stored on escape routes **No**

Summary / Observations

Cars parking too close to the building, restrict parking to along kerb line only at least 5m away from building

Imagery

Measures to Limit Fire Spread and Development

Is fire compartmentation of a reasonable standard? **Yes**

Do flat front doors that lead onto a common escape route appear to be FD30 and fitted with a self-closing device? **Yes**

Are they notional? **Yes**

Are they certified? **No**

Risk assess 25% of entrance doors to residents' accommodation to ensure they are fire resisting and self-closing. Over the next 3 fire risk assessments 100% of doors will need to have been systematically assessed. List the dwelling numbers inspected. If failings are identified please include in observations and action plan.

| Door examined | Does the door need an assessment? | Fire Resistance adequate | Adequately Self Closing | Fitted with suitably sized door stops or intumescent strips and cold smoke seals |
|-----------------|-----------------------------------|--------------------------|-------------------------|--|
| THOMASPLAC_D004 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D007 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D013 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D018 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D025 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D027 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D032 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D048 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D001 | Yes | Yes | Yes | Yes |

| | | | | |
|-----------------|-----|-----|-----|-----|
| THOMASPLAC_D008 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D015 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D016 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D017 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D019 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D021 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D022 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D026 | Yes | No | Yes | Yes |
| THOMASPLAC_D028 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D029 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D030 | Yes | Yes | No | Yes |
| THOMASPLAC_D037 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D038 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D041 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D042 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D043 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D044 | Yes | Yes | Yes | Yes |

| | | | | |
|-----------------|-----|-----|-----|-----|
| THOMASPLAC_D050 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D055 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D057 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D005 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D009 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D010 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D020 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D023 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D034 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D051 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D052 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D052 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D053 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D054 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D056 | Yes | Yes | No | Yes |
| THOMASPLAC_D002 | Yes | No | Yes | Yes |
| THOMASPLAC_D003 | Yes | Yes | Yes | Yes |

| | | | | |
|-----------------|-----|-----|-----|-----|
| THOMASPLAC_D006 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D011 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D012 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D014 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D024 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D031 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D033 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D035 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D036 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D039 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D040 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D045 | Yes | Yes | No | Yes |
| THOMASPLAC_D046 | Yes | Yes | No | Yes |
| THOMASPLAC_D047 | Yes | Yes | Yes | Yes |
| THOMASPLAC_D049 | Yes | Yes | Yes | Yes |

Is there a reasonable limitation of linings that may prevent fire spread? (Class 0 linings)? **Yes**

Is suitable means of ventilating the common areas provided? **Yes**

On review of the last 12 months of repairs history and SIP works, have any works taken place which have impacted on the communal compartmentation? **Yes**

Section 8 Summary / Observations

SIP WORKS: Internal redecoration have been undertaken at the scheme, fire doors removed and refitted to facilitate new carpets, these have required trimming down in various areas.

Imagery

Escape Lighting

Do common areas have a reasonable standard of emergency lighting? **Yes**

Section 9 Summary / Observations

Lighting meets requirements of BS:5266

Imagery

Fire Safety and Notices

Are Safety Signs and Notices provided to a reasonable standard and displayed on escape routes?

No

Section 10 Summary / Observations

Directional fire Signage has been removed and not replaced to meet requirements of BS: 5499

Imagery

Fire Fighting Equipment

Is the provision of portable FFE in accordance with the organisation's policy **Yes**

Are hose reels provided in the premises? **No**

If 'yes' can they be removed?

And

Are they clearly marked 'this equipment is out of use and operation'?

Section 11 Summary / Observations

Scheme benefits from a manually operated fixed wet foam dispersal system above the fryers and a emergency gas shut off valve within the commercial kitchen.

Imagery

Automatic Fire Systems i.e. suppression system

Is there an automatic fire system present? **Yes**

What type of system is provided? **Ansul wet foam system installed above fryers within commercial kitchen Gas shut off valve within the commercial kitchen**

Section 12 Summary / Observations

Imagery

Other Relevant Fixed Systems

Type of system(s) provided

Automatic/Manual/Mechanical or Natural Smoke Ventilation Systems? **Yes**

Last Service Date **03/06/2024**

Dry or wet risers? **Dry**

Last Service Date **01/09/2023**

Fire-fighting lifts? **Yes**

Last Service Date **No date provided**

Other **No**

Please Specify **Ansul wet foam system**

Last Service Date **10/09/2024**

Section 13 Summary / Observations

Imagery

Access by Emergency Services

Is adequate access available for Fire Service vehicles? **Yes**

Is the assembly point positioned in a suitable location? **Yes**

Section 14 Summary / Observations

Imagery

Management of Fire Safety

The court manager/Fire Safety Manager shall maintain the existing emergency fire evacuation plan and procedures.

The Court Fire Plan should be provided and located in the Fire Box. The plan should contain a building layout plan indicating the locations of the main Gas Shut off valve for the building/main Electrical Isolation Switch/location of the Lift Motor Room and Service User Criteria document (including location of any gas Cylinders (oxygen) on the premises used by residents).

Is the Fire Risk Management folder in place and maintained?

- Fire Safety Training Records
- Fire Alarm System tests
- Emergency Lighting tests
- Portable fire equipment
- Fires and False Alarm Records

If yes number recorded in past 12 months

Is there a current Court Fire Plan in place?

Have all staff been provided with a basic level of fire safety training and instruction on induction?

Are all staff given periodic fire safety 'refresher training' at regular intervals?

Is there a suitable record of agreement amongst duty holders as to responsibilities for all relevant aspects of fire safety management? (Fire Safety Responsibilities Matrix)

Are third-party staff (i.e. carers/contractors) provided with appropriate instruction and training regarding fire safety management and evacuation arrangements?

Are the fire evacuation procedures clear to visitors etc?

Is appropriate liaison maintained with the local Fire Brigade?

Has information been provided to residents regarding buildings evacuation strategy?

Section 15 Summary / Observations

Imagery

Testing and Maintenance

Is a testing and maintenance regime in place for components located in the communal areas?

Yes

Are the following maintained and tested by the service contractors in accordance with the relevant standard:

Fire Alarm **Yes**
Last date Fire Alarm tested **26/01/2024**

Emergency Lighting **Yes**
Last date Emergency Lighting tested **22/01/2024**

Fire Fighting Equipment **Yes**

Rising Main **Yes**

Sprinkler / automatic suppression system installation **Yes**

Are routine checks of final fire exit doors and/or security fastenings undertaken? **Yes**

Is the lightning protection system inspected annually and tested? **Yes**

Is the smoke extraction system maintained and tested? **Yes**

Other relevant inspections or tests: **Yes**

Comments

LAST SERVICE DATES: FFE: Kitchen suppression system: 9/2023 Dry riser: 9/2023 Lightning: 8/2024 Catering kitchen extract system: 3/2024 Gas plant 18/3/24 Kitchen Fire shutter: 5/2024 Fire fighting lift: 8/2024

Section 16 Summary / Observations

Currently FRS lift is out of service, repair has been ordered via OTIS.

Imagery

Resident Engagement

Has the resident's engagement session taken place?

When did the resident's engagement session take place? **No date provided**

Section 17 Summary / Observations

Imagery

RISK LEVEL

NB: Although the purpose of this section is to place the fire risk in context, the approach to fire risk assessment is subjective and for guidance only. All hazards and deficiencies identified in this report should be addressed by implementing all recommendations contained in the Action Plan.

| | | | | | | |
|---|---|--------------------------------------|---|---|--|----|
| PROBABILITY/ fire or hazard to life | Almost certain | 5 | 10 | 15 | 20 | 25 |
| | More likely than not | 4 | 8 | 12 | 16 | 20 |
| | Possible | 3 | 6 | 9 | 12 | 15 |
| | Less likely to happen | 2 | 4 | 6 | 8 | 10 |
| | Remote | 1 | 2 | 3 | 4 | 5 |
| SEVERITY/Potential consequences of fire | Minor injury or insignificant damage to property. | Injury, or slight damage to property | Serious injury, or limited damage to property | Serious injury or fatality. Critical damage to property | Multiple fatalities, catastrophic loss of business | |

Taking into account the fire safety measures, the nature of the building - it's use and occupants, fire safety protection and procedural arrangements observed at the time of this Fire Risk Assessment, it is considered that the risk level is:

Slight harm: Outbreak of fire unlikely to result in serious injury or death of any occupant (other than an occupant sleeping in a bedroom in which a fire occurs)

ACTION PLAN: and Significant findings

Court name: **Thomas Place**

Address: **James Whatman Way, MAIDSTONE**

The following recommendations should be implemented in order to reduce fire risk to, or maintain it at, the appropriate level.

| Risk ID | Risk Level | Risk Owner | Comments | Deadline |
|----------------------|---------------|----------------------|--|-------------------|
| Risk ID- 5097 | Medium | Court Manager | Door adjustments: 7th floor bin room - not closing 7th floor corridor - intu strip missing 4th floor bin room - not closing Corridor ADJ 21 - not closing Guestroom 2 - gap top of door Lounge door - not closing when door fully opened Dining room to corridor door - not closing/weak closing when fully opened F26 - gap along door head F2 - not closing into frame F46 - not closing F56 - freeswing not operational F45 - not closing F30 - door closer not holding door on powered assist | 11/09/2025 |
| Risk ID- 5098 | Medium | Court Manager | Missing fire action directional signage - replace as necessary | 11/09/2025 |
| Risk ID- 5101 | Medium | Court Manager | Parking clsoe to the building, cars to park 5m away from the building alongside the kerb. | 11/09/2025 |
| Risk ID- 5096 | Low | Court Manager | Buggy room charge points - investigate and resolve charge points not being fitted to a timed supply, temporay measure Care Team to record daily when switches are isolated at night. | 11/03/2026 |
| Risk ID- 5099 | Medium | Court Manager | Catering kitchen staff to amend fire strategy action plan to identify the need to shut off gas supply and manually operate supression system. | 11/09/2025 |

| Risk ID | Risk Level | Risk Owner | Comments | Deadline |
|----------------------|---------------|----------------------|--|-------------------|
| Risk ID- 5100 | Medium | Court Manager | Fire service lift out of service - ordre has been raised to OTIS regarding this | 11/09/2025 |

*Action Plan Timescales

High Risks

Action should be undertaken immediately or as quickly as practically possible and within three months by the identified lead person/department.

Moderate Risks

Action should be undertaken as quickly as is practically possible, usually within twelve months by the lead person/department.
Where moderate risks form part of the planned programme of fire compartmentation upgrade works, these will be completed in line with Housing 21's agreed risk based planned works strategy*.

Low Risks

Low risks will continue to be reviewed and should be actioned when practically possible.

Planned Works Strategy

Housing 21 has a risk-based fire compartmentation strategy:

High risk schemes (3 stories and over) will be prioritised over low rise schemes.
Category 2 schemes will be prioritised over category 1 schemes.
Older schemes will be prioritised over newer schemes.

Housing 21 believes this approach is pragmatic, concentrating on the level of risk whilst committing substantial resources to court improvements.



